

Wall Mounted
 CT Check Meter Box
 Size: 3'-0" x 3'-0" x 1'-6"
 DG Set- 25 KVA
 Size: 2200 L X 900 W X 1375 H
 Weight Kgs. 880KG
 Fuel Cons.- 4.8 Lit/ Hr

Wall Mounted
CT Check Meter Box
Size: 3'-0" x 3'-0" x 1'-6"

Incoming HT
Xlpe Cable
Earthing
Pit


HT Switch

160 KVA 11kV/433V
TRANSFORMER
E 1380 L X1130 W X1655 H
WITH FOUNDATION &
MARGIN AS PER
REQUIREMENT

Lighting
Arrester

Model: Stormmaster - ESE - 30
(Level 2/Medium Protection)
(Protection radius - 25M, Meet
Height - 2 Mtr)

LED Aviation Light Luminaires
Product Code - 110731
Cat No. - BGAV 302 LED
Make - BALAJI



EARTHING DETAILS

- [illegible]

NOTES:

1. ALL NEUTRAL EARTHS TO BE CONNECTED TO 50 X 3 GI EARTH STRIP FROM EARTH PIT TO EQUIPMENT.
2. ALL BODY EARTHS TO BE CONNECTED TO 25 X 3 GI EARTH STRIP FROM EARTH PIT TO EQUIPMENT.

VIPUL AGARWAL
M.E.P. CONSULTANT
B.E. ELECTRICAL

SERVICES CONSULTANT:
VIPUL CONSULTING,
F 9/440, Chitrakut Scheme, Jaipur
PH: 91-0-93146-10438, 0141-2440946
Mail: vipul8599@yahoo.com
DATE: -30-07-2020 REV.-01

DATE:-30-07-2020 REV:-01

PROPOSED FLAT AT
JAGATPURA

DWG TITLE-

STILT FLOOR
ELECTRIC SUB-STATION,
CABLE CHAMBER PIPE
ROUTE & LIGHTNING
ARRESTER PLAN

DATE: -

30-07-2020
DEALT BY

SANJAY

SANJAY
APPD. BY-

VPUL AGARWAL
ARCHITECTS:-

Plot No. 65, 66, 81, 82, Scheme 1 PRM SHGAR, Jaipur Rajasthan

