

नगर निगम, जयपुर ग्रेटर

(राजस्थान नगरपालिका अधिनियम 2009 की धारा के अन्तर्गत)

अनापत्ति प्रमाण पत्र

आवेदन नं.: LSG/JAIPUR GREATER/FIRENOC/2022-23/8412
जारी दिनांक: 11-JAN-2023

प्रेषित-

आवेदक का नाम श्री/श्रीमती: BASU DEO SHARMA SHARMA
आवेदक का पता: JAIPUR

विषय:- अग्निशमन अनापत्ति प्रमाण पत्र जारी करने बाबत

आपके भवन RUDRAKSHA II, ASHADEEP GREEN VISTA, VILLAGE SHRIKISHANPURA SECTOR 37, TEHSIL SANGANER, JAIPUR GREATER, JAIPUR, RAJASTHAN का निरीक्षण किया गया निरीक्षण के दौरान अग्नि सुरक्षा उपकरण सही पाए गए अतः उपरोक्त सुरक्षा व्यवस्था के अनुसार निम्न शर्तों पर पाबंद करते हुए यह स्थाई (Permanent) अनापत्ति प्रमाण पत्र जारी किया जाता है।

शर्तें:-

- अनापत्ति प्रमाण पत्र जारी करने की तिथि से एक वर्ष की अवधि हेतु ही मान्य होगा। एक वर्ष बाद अनापत्ति प्रमाण पत्र का नवीनीकरण किया जाना आवश्यक होगा, अन्यथा अनापत्ति स्वतः निरस्त मानी जावेगी।
- भवन के समस्त स्टाफ व सिक्योरिटी गार्ड्स को वर्ष में कम से कम दो बार अग्निशमन विभाग द्वारा प्रशिक्षण दिलाना आवश्यक होगा।
- अग्निशमन उपकरण समयावधि में रीफिल कराना होगा।
- निरीक्षण के दौरान आवश्यक दिशा निर्देशों का पालन करना आवश्यक होगा।
- यदि राज्य सरकार या निगम द्वारा भविष्य में कोई नियम/उपनियम जारी किया जाता है तो प्रबंधक को मान्य होगा।
- भवन का मुख्य अग्निशमन अधिकारी द्वारा कभी भी निरीक्षण किया जा सकेगा व फायर सिस्टम कार्यरत नहीं पाए जाने की स्थिति में यह अभिशंषा पत्र निरस्त माना जाएगा।
- पानी के टैंक हर समय भरे रखने होंगे व पम्प व पूरा फायर सिस्टम 24 घण्टे कार्यशील स्थिति में रखने को बाध्य होंगे।
- फायर सिस्टम को चलाने हेतु 24 घंटे फायर प्रशिक्षित कर्मचारी रखने होंगे तथा ए एम सी करवायी जाकर सिस्टम का रख रखाव व संचालन करना अनिवार्य होगा।
- फायर वाहन आसानी से आ जा सके इसके लिए पर्याप्त खुला स्थान अवरोध रहित रखना होगा।
- भवन के अंदर किसी भी प्रकार का विस्फोटक पदार्थ व अति ज्वलनशील पदार्थ नहीं रखा जावे।
- रोप लेडर व दो रस्सा भवन के सभी टावर में टावर कि उंचाई जितना हर समय भवन में रखना होगा।
- यह अग्नि सुरक्षा प्रमाणपत्र अग्नि सुरक्षा की दृष्टि से ही मान्य होगा।
- भूमि व भवन संबंधित किसी भी प्रकार के विवाद हेतु यह पत्र बतौर साक्ष्य मान्य नहीं होगा एवं इस बाबत आवेदक स्वयं उत्तरदायी होगा।
- यह अनापत्ति प्रमाण पत्र रूफटॉप रेस्टोरेट के लिए मान्य नहीं है। जिस भाग के लिए अनापत्ति प्रमाण पत्र जारी किया जा रहा है वहां पर रूफटॉप रेस्टोरेट का संचालन पूर्णतया प्रतिबंधित रहेगा।

अग्निशमन अधिकारी
नगर निगम, जयपुर ग्रेटर




Signature Not Verified

Digitally signed by Monika Soni
Designation : DC/EO/Commissioner
Date: 2023.01.11 17:41:29 IST
Reason: Approved

NOTE:-
OUTDOOR HYDRANT USED AS PER SITE CONDITION

CLIENT:-
"ASHADEEP GROUP"



ARCHITECTS :
m|a|a|r|c|h|i|t|e|c|t|s
ARCHITECTS, ENGINEERS AND INTERIOR DESIGNERS
PLOT No. 7, OFF. SAHAKAR NAGAR,
LAKHOTI SCHEME, JAIPUR - 302015
TEL. 91-0141-2741232, 91-0141-2745819
TELE FAX 91-0141-2741684
email - studio@maarchitects.in, maarchitects@gmail.com
web - www.maarchitects.in

SERVICES CONSULTANTS:
A ONE INFRACONSULTANTS PVT.LTD.

7 KHA 13 JAWAHAR
NAGAR, JAIPUR.
94437742, 0141-420742
geneshone2005@yahoo.co.in
www.a-oneinfraconsultants.com, www.
aoneconsultants.co.in

259 SHIPRA SUN CITY
GHAZIABAD INDIA
9837018581
rajivsharma32002@yahoo.com

PROJECT :-
ASHADEEP GROUP
"RUDRAKSH-I & II"
(Lig & Ews)

Ar. Balwant Prem Singh Rathore
E. Arch.
CA/2014/648&B

NAME OF DRAWING:-
Outer Fire Fighting
Detail



DRAWN BY: APPROVED BY:
Navratan S.K.M.

SCALE: REV. NO.: DATE:
R-4 24-11-2024

DRAWING NO.: NORTH:

CLIENT:-

"ASHADEEP GROUP"



ARCHITECTS :
 ml architects
 ARCHITECTS, ENGINEERS AND INTERIOR DESIGNERS
 PLOT No.-1, OFF SAHAKAR MARG,
 LAL, NOTRI SCHEME, JAIPUR - 302015
 TEL: 91-0141-2741232, 91-0141-2743619
 TELE FAX: 91-0141-2741664
 email - studio@mlarchitects.in, mlarchitects@gmail.com
 web - www.mlarchitects.in

SERVICES CONSULTANTS:
 A ONE INFRACONSULTANTS PVT.LTD.

7 KHA 13 JAWAHAR
 NAGAR, JAIPUR.
 944377142, 0141-4020142
 ganeshsone2005@yahoo.co.in
 www.a-oneconsultants.com, www.
 aoneconsultants.co.in
 299 SHEPRA SUN CITY
 GRAZABAD INDIA
 987018383
 raj@barmas32002@yahoo.com



PROJECT :-
 ASHADEEP GROUP
 RUDRAKSH-I & II
 (Lig & Ews)
 A-1: Balwant, Preet Singh Rathore
 B. Arch.
 CA/2014/64848

NAME OF DRAWING:-
 Terrace Floor Fire
 Fighting Detail

DRAWN BY: Navratan
APPROVED BY: S.K.M.

SCALE : R-2
REV. NO. :
DATE : 05-09-2019
DRAWING NO. :
NORTH:

S.NO.	NBC Clause no.	Requirment as per NBC	Status as per drawing
1.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Fire Extinguisher	Provided at entrance gate, lobby & staircase.
2.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Hose Reel	Provided on landing of fire staircase at every floor.
3.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Wet Riser	Provided on landing of fire staircase at every floor.
4.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Yard Hydrant	Provided at entrance gate & set back area
5.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Automatic Sprinkler System	To be installed in entire building
6.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Manually Operated Electric Fire Alarm System	Provided on landing of fire staircase at every floor.
7.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Automatic Delection and Alarm System	Provided on landing of fire staircase at every floor.
8.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Under Ground Water Tank	Not Required
9.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Over Head Fire Tank Pump	Required 900lpm
10.	4.18.2, 6.1.2 & Table-23 (Fire Detection & Extinguishing System)	Under Ground Water Tank Fire Pump	Provided on Terrace floor Cap:- 25 KL
			Not Required

CLIENT

ASHADEEP GROUP


ARCHITECT

m|a|a|r|c|h|i|t|e|c|t|s
ARCHITECTS, ENGINEERS AND
INTERIOR DESIGNERS

PLOT No.-1, OFF SAHAKAR MARG,
LAL KOTHI SCHEME, JAIPUR - 302015
TEL. 91-0141-2741232, 91-0141-2743619
TELE FAX. 91-0141-2741664
email - studio@maarchitects.in, maarchitects@gmail.com
web - www.maarchitects.in

SERVICES CONSULTANTS(ELE.):

LANDSCAPE CONSULTANTS



SERVICES CONSULTANTS(P):
A ONE INFRACONSULTANTS PVT.LTD.



7 KHA 13 JAWAHAR NAGAR
JAIPUR
9414377742, 0141-4020742
ganeshhone2005@yahoo.co.in
aoneinfraconsultants@yahoo.in

259 SHIPRA SUN CITY
GHAZIABAD INDIA
rajivsharma632002@yahoo.com
www.aoneinfra.com

TITLE:-
" Rudraksh-II "
Tower- A TO F
Jaipur

PROJECT:-
Jaipur
" Rudraksh-II "

NAME OF DRAWING:
FIRE SCHEMATIC DIAGRAM
(FOR TYPICAL SHAFT)

DEALT BY:
Navratan

APPROVED BY:
S.K.M.

DRAWING
FIRE DRAWING

NORTH
N

PROJECT NO.:

DATE:
05-09-2019

SCALE:

REV NO.:



DRAWING NO.:

PROJECT / CATEGORY / BLOCK / FLOOR / TYPE / NUMBER

LEGEND :-

	NRV	NON RETURN VALVE
	PG	PRESSURE GAUGE
	BV	BUTTERFLY VALVE
	AV.	AIR VESSEL
	F.H.	FLOOR HYDRANT
	I.C.V.	INSTALLATION CONTROL VALVE
	FS	FLOW SWITCH
	F.B.C	FIRE BRIGADE CONNECTION
	YH	YARD HYDRANT
	FHC	FIRE HYDRANT CABINATE
	HR	HOSE REEL
	FRB	FLEXIBLE RUBBER BELLOW
	Y-ST.	Y - STRAINER

FIRE HOSE CABINET	
FIRE HOSE STATION COMPRISING OF:	
1. 1 NO. HOSE REAL DRUM WITH 30mtr.	
2. 1 NO. BRANCH PIPE.	
3. 2 NOS FIRE EXTINGUISHERS.	
FIRE PUMP DETAIL	CAP.
F1 FIRE PUMP AT TERRACE	900 lpm



Ar. Balwant Prem Singh Rathore
B. Arch.
CA/2014/64848

