


RING 5 FOR RMU 8,9,10(27-28,21-22)  
 RING 6 FOR RMU 11,12(23-24,25-26)  
 RING 7 FOR COMMERCIAL  
 RING 8 FOR COMMERCIAL FACILITY TRANSFORMER & 315 KV  
 A TO B -4 HT CABLE IN TRENCH  
 B TO C -3 HT CABLE IN TRENCH  
 C TO D -2 HT CABLE IN TRENCH  
 D TO E -1 HT CABLE IN TRENCH

From	To	No of Cables	Trench Type
1	2'	12	Composite(LT+HT)
2'	3	12	Only LT
3	4	8	Only LT
4	5	4	Only LT
5	6	8	Composite(LT+HT)
6	7	14	Composite(LT+HT)
7	8	6	Composite(LT+HT)
8	9	6	Composite(LT+HT)
9	10	4	Only LT
10	11	8	Composite(LT+HT)
11	12	12	Composite(LT+HT)
12	13	8	Composite(LT+HT)
13	14	4	Composite(LT+HT)
14	15	4	Composite(LT+HT)
15	16	4	Composite(LT+HT)

RMU 8 for B-27 & B-28 (630kVA)  
 RMU 9 for B-21 & B-22 (630kVA)  
 RMU 10 for B-20 (500kVA)  
 RMU 11 for B-25 & B-26 (630kVA)  
 RMU 12 for B-23 & B-24 (630kVA)  
 RMU 13 for Common facility (315kVA)

for CHOWDHURY & ASSOCIATES  
  
 (P.K.CHOWDHURY)